

AGA CERTIFIED PRODUCT



www.jas-anz.org/register

Certificate Holder: **POLIX EXPORT d.o.o**

ABN/ACN No. (if applicable): **N/A**

Manufacturer: **Polix Export d.o.o**

Agent (if applicable): **All Valve Industries Pty Ltd**

Type of Component: **Ball Valve - Manual Shut-off valve**
Temperature Range -20°C-60°C
Rated Working Pressure 1600kPa

Model No. & Description: **Polix**
KPC-G Series
KPC-G DN32, KPC-G DN40, KPC-G DN50,
KPC-G DN65, KPC-G DN80, KPC-G DN100,
KPC-G DN125, KPC-G DN150 &
KPC-G DN200

Relevant Standard(s): **AS 4617-2004 (Including Amendment 2)**

This is to certify that the particular **COMPONENT** specifically described herein and supplied to The Australian Gas Association (hereafter called the AGA) by the Certificate Holder named above has been subject to "type-testing" and assessed by the AGA to comply with the requirements of the AGA's Product Certification Scheme for Type Tested Gas Products.

This Certificate is issued on the express conditions that:

- (i) The Certificate Holder undertakes to comply with the Rules Governing The AGA's Product Certification Scheme (hereafter called the Rules Governing);
- (ii) This Certificate remains the property of the AGA; and
- (iii) The AGA reserves the right to cancel this Certificate in accordance with the Rules Governing, and in such an event the Certificate Holder undertakes to surrender the Certificate to the AGA upon request.




Client Manager


Certificate Authorised

Certificate first issued: **2 September 2009**

Certificate No: **7517**

This copy valid from: **12 March 2020**

Refer specification issue: **05**